



**THE CORPORATION OF THE CITY OF WINDSOR
OFFICE OF THE CITY SOLICITOR**

ALEX VUCINIC

**Manager of Purchasing
& Risk Management**

**Dawn Lamontagne
Supervisor of Purchasing**

**(519) 255-6272
TELEPHONE NUMBER**

**ADDENDUM NO. 3
TENDER NO. 43-24
LRWRP DEWATERING BUILDING SLUDGE HOLDING TANK REHABILITATION
March 20, 2024**

This addendum amends and forms part of the Tender Documents. The bidder shall insert the addendum behind the cover page of the Tender Documents.

PLEASE NOTE: The closing date has been extended to ELEVEN-THIRTY FIFTY-NINE (11:30:59) A.M. (E.D.T.), WEDNESDAY, MARCH 27th, 2024.

QUESTIONS/ANSWERS:

Question #1: We find that the time allowed to complete the work is insufficient especially due to the fact of any unknown patching, drying times of materials and curing times stated by material manufacturers. Therefore, we request extra time to complete the scope

Answer: The maximum allowed duration for each shutdown is 4 days. We cannot extend the 'out of service' time.

Except for the contents of this addendum, all other terms and conditions of this tender remain the same.

END OF ADDENDUM NO. 3

Yours truly,

THE CORPORATION OF THE CITY OF WINDSOR

Dawn Lamontagne
Supervisor of Purchasing

DL/jm

**ADDENDUM NO. 3
TENDER NO. 43-24
LRWRP DEWATERING BUILDING SLUDGE HOLDING TANK REHABILITATION
March 20, 2024**

I hereby acknowledge receipt of Addendum No. 3 to the Tender No. 43-24 (2 pages).

The information contained therein is hereby noted and account of same will be taken in our tender cost.

This information was received on the _____ day of _____, 20_____.

Signature

Name (Printed)

Company Name

***NOTE: You are required to acknowledge this addendum with your TENDER submission.**