

ALEX VUCINIC

**Manager of Purchasing
& Risk Management**

**Dawn Lamontagne
Supervisor of Purchasing**

**(519) 255-6272
TELEPHONE NUMBER**

ADDENDUM NO. 1

TENDER NO. 43-24

LRWRP DEWATERING BUILDING SLUDGE HOLDING TANK REHABILITATION

March 18, 2024

This addendum amends and forms part of the Tender Documents. The bidder shall insert the addendum behind the cover page of the Tender Documents.

Question:

The notes on Drawing S-701 (as well as the red line note found on the original Drawing M-7) request the replacement of nuts and bolts with new Stainless Steel ones. It is difficult to determine the number of holes or bolts on the flanges in the provided photos. Typically, a flange for a nominal size of 10" (250mm) would have 12 holes for Class 150 and 16 for Class 300. Could you please advise if the flanges adhere to the B16.5 standard and specify their pressure class?

Response:



A1-1

	<ul style="list-style-type: none"> Attached is a photo showing the number of holes on a flange. The exact number of holes, or bolts on the flanges is unclear in the photos attached. It is acceptable to provide a tender based on 12 bolts/holes on a flange. It is unknown whether the existing flanges are B16.5 standard or not. Since the piping flanges are near the discharge end inside the chamber, the pressure class is relatively low in the range of 25 psi.
<p>A1-2</p>	<p>Question:</p> <p>Can you confirm how many shutdowns are allowed?</p> <p>Response:</p> <p>The proposed tank recoating and drain pipe relining must be completed in two separate shutdowns. Shutdowns should be coordinated for dry-weather periods. The maximum allowed duration for each shutdown is 4 days.</p>
<p>A1-3</p>	<p>Question:</p> <p>Can you specify the hours during which work is allowed during these shutdowns?</p> <p>Response:</p> <p>Shutdown days and times are weather-dependent and must occur during dry-weather days.</p> <p>➤ First Shutdown (4 days) - Includes Drain Pipe Relining.</p> <ul style="list-style-type: none"> Start Day and Time: Friday at 10:00 am (SHT will be drained by LRWRP staff before 10.00 am on Friday) End Day and Time: Tuesday at 10:00 am (Ready for LRWRP operation by 10:00 am, Tuesday) <p>➤ Second Shutdown (4 days) – Includes Sludge Holding Tank (SHT) pressure washing and application of protective coating inside SHT. This shutdown has to be scheduled at least 2 weeks apart.</p>

	<ul style="list-style-type: none">• Start Day and Time: Friday at 10:00 am (SHT will be drained by LRWRP staff before 10.00am on Friday)• End Day and Time: Tuesday at 10:00 am (Ready for LRWRP operation by 10:00 am, Tuesday)
--	---

Except for the contents of this addendum, all other terms and conditions of this tender remain the same.

END OF ADDENDUM NO. 1

Yours truly,

THE CORPORATION OF THE CITY OF WINDSOR

Alex Vucinic .

Alex Vucinic
Manager of Purchasing & Risk Management

AV/jm

**ADDENDUM NO. 1
TENDER NO. 43-24
LRWRP DEWATERING BUILDING SLUDGE HOLDING TANK REHABILITATION
March 18, 2024**

I hereby acknowledge receipt of Addendum No. 1 to the Tender No. 43-24 (5 pages).

The information contained therein is hereby noted and account of same will be taken in our tender cost.

This information was received on the _____ day of _____, 20____.

Signature

Name (Printed)

Company Name

***NOTE: You are required to acknowledge this addendum with your TENDER submission.**

